

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

Influent Flow and Loading

1. Monthly Average Flows and (C)BOD Loadings

1.1 Verify the following monthly flows and (C)BOD loadings to your facility.

Influent No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average (C)BOD Concentration mg/L	x	8.34	=	Influent Monthly Average (C)BOD Loading, lbs/day
January	1.2085	x	267	x	8.34	=	2,689
February	1.2614	x	265	x	8.34	=	2,788
March	1.2247	x	270	x	8.34	=	2,761
April	1.2658	x	272	x	8.34	=	2,870
May	1.3716	x	224	x	8.34	=	2,562
June	1.3055	x	224	x	8.34	=	2,435
July	1.2482	x	234	x	8.34	=	2,439
August	1.2172	x	240	x	8.34	=	2,438
September	1.3048	x	266	x	8.34	=	2,892
October	1.3308	x	274	x	8.34	=	3,037
November	1.2890	x	293	x	8.34	=	3,148
December	1.2527	x	301	x	8.34	=	3,150

2. Maximum Monthly Design Flow and Design (C)BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	1.824	x	90	=	1.6416
		x	100	=	1.824
Design (C)BOD, lbs/day	3152	x	90	=	2836.8
		x	100	=	3152

2.2 Verify the number of times the flow and (C)BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times (C)BOD was greater than 90% of design	Number of times (C)BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	0	0	0	0
April	1	0	0	1	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	1	0
October	1	0	0	1	0
November	1	0	0	1	0
December	1	0	0	1	0
Points per each		2	1	3	2
Exceedances		0	0	5	0
Points		0	0	15	0
Total Number of Points					15

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?
 Yes Enter last calibration date (MM/DD/YYYY)

No

If No, please explain:

4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

Yes

No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

Yes

No

If Yes, please explain:

5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks

Holding Tanks

Grease Traps

Yes

Yes

Yes

No

No

No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

Yes

gallons

No

Holding Tanks

Yes

gallons

No

Grease Traps

Yes

gallons

No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

Yes

No

If yes, describe the situation and your community's response.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

<p><input type="radio"/> Yes</p> <p><input checked="" type="radio"/> No</p> <p>If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	
--	--

Total Points Generated	15
Score (100 - Total Points Generated)	85
Section Grade	B

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

Effluent Quality and Plant Performance (BOD/CBOD)

1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	8	1	0	0
February	30	27	8	1	0	0
March	30	27	7	1	0	0
April	30	27	6	1	0	0
May	30	27	4	1	0	0
June	30	27	3	1	0	0
July	30	27	3	1	0	0
August	30	27	2	1	0	0
September	30	27	4	1	0	0
October	30	27	6	1	0	0
November	30	27	7	1	0	0
December	30	27	5	1	0	0

* Equals limit if limit is <= 10

Months of discharge/yr	12		
Points per each exceedance with 12 months of discharge		7	3
Exceedances		0	0
Points		0	0
Total number of points			0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

- Yes Enter last calibration date (MM/DD/YYYY)

02/23/17

- No

If No, please explain:

3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

none

4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

- Yes

- No

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

<p>If Yes, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>
<p>4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?</p> <p><input type="radio"/> Yes</p> <p><input checked="" type="radio"/> No</p> <p>If Yes, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>
<p>4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?</p> <p><input type="radio"/> Yes</p> <p><input type="radio"/> No</p> <p><input checked="" type="radio"/> N/A</p> <p>Please explain unless not applicable:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

Effluent Quality and Plant Performance (Total Suspended Solids)

1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	6	1	0	0
February	30	27	4	1	0	0
March	30	27	4	1	0	0
April	30	27	3	1	0	0
May	30	27	3	1	0	0
June	30	27	3	1	0	0
July	30	27	3	1	0	0
August	30	27	2	1	0	0
September	30	27	4	1	0	0
October	30	27	5	1	0	0
November	30	27	4	1	0	0
December	30	27	4	1	0	0

* Equals limit if limit is <= 10

Months of Discharge/yr	12		
Points per each exceedance with 12 months of discharge:		7	3
Exceedances		0	0
Points		0	0
Total Number of Points			0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

Effluent Quality and Plant Performance (Ammonia - NH3)

1. Effluent Ammonia Results

1.1 Verify the following monthly and weekly average effluent values, exceedances and points for ammonia

Outfall No. 001	Monthly Average NH3 Limit (mg/L)	Weekly Average NH3 Limit (mg/L)	Effluent Monthly Average NH3 (mg/L)	Monthly Permit Limit Exceedance	Effluent Weekly Average for Week 1	Effluent Weekly Average for Week 2	Effluent Weekly Average for Week 3	Effluent Weekly Average for Week 4	Weekly Permit Limit Exceedance
January	5.7		.083076923	0					
February	5.7		.504615385	0					
March	5.7		.258823529	0					
April	5.7		.353076923	0					
May		2			.4264	.276333333	.215	.071666667	
June		2			.066666667	.078333333	.066666667	.083	
July		2			.107	.099333333	.137666667	.104	
August		2			.089	.086333333	.102	.073666667	
September		2			.077	.369	.36	.170333333	
October		2			.231	.527333333	.099666667	.230666667	
November	5.7		1.5103125	0					
December	5.7		.273153846	0					
Points per each exceedance of Monthly average:									10
Exceedances, Monthly:									0
Points:									0
Points per each exceedance of weekly average (when there is no monthly average):									2.5
Exceedances, Weekly:									0
Points:									0
Total Number of Points									0

NOTE: Limit exceedances are considered for monthly OR weekly averages but not both. When a monthly average limit exists it will be used to determine exceedances and generate points. This will be true even if a weekly limit also exists. When a weekly average limit exists and a monthly limit does not exist, the weekly limit will be used to determine exceedances and generate points.

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

Effluent Quality and Plant Performance (Phosphorus)

1. Effluent Phosphorus Results

1.1 Verify the following monthly average effluent values, exceedances, and points for Phosphorus

Outfall No. 001	Monthly Average phosphorus Limit (mg/L)	Effluent Monthly Average phosphorus (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	1.5	0.299	1	0
February	1.5	0.149	1	0
March	1.5	0.184	1	0
April	1.5	0.149	1	0
May	1.5	0.151	1	0
June	1.5	0.334	1	0
July	1.5	0.454	1	0
August	1.5	0.132	1	0
September	1.5	0.180	1	0
October	1.5	0.466	1	0
November	1.5	0.226	1	0
December	1.5	0.148	1	0
Months of Discharge/yr			12	
Points per each exceedance with 12 months of discharge:				10
Exceedances				0
Total Number of Points				0

0

NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

Biosolids Quality and Management

1. Biosolids Use/Disposal

1.1 How did you use or dispose of your biosolids? (Check all that apply)

- Land applied under your permit
- Publicly Distributed Exceptional Quality Biosolids
- Hauled to another permitted facility
- Landfilled
- Incinerated
- Other

NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.

1.1.1 If you checked Other, please describe:

3. Biosolids Metals

Number of biosolids outfalls in your WPDES permit:

3.1 For each outfall tested, verify the biosolids metal quality values for your facility during the last calendar year.

Outfall No. 002 - SLUDGE TO WCWBF

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75	<4.9													0	0
Cadmium		39	85	.47													0	0
Copper		1500	4300	540													0	0
Lead		300	840	9.9													0	0
Mercury		17	57	<1.4													0	0
Molybdenum	60		75	20												0		0
Nickel	336		420	18												0		0
Selenium	80		100	<7												0		0
Zinc		2800	7500	770													0	0

3.1.1 Number of times any of the metals exceeded the high quality limits OR 80% of the limit for molybdenum, nickel, or selenium = 0

Exceedence Points

- 0 (0 Points)
- 1-2 (10 Points)
- > 2 (15 Points)

3.1.2 If you exceeded the high quality limits, did you cumulatively track the metals loading at each land application site? (check applicable box)

- Yes
- No (10 points)
- N/A - Did not exceed limits or no HQ limit applies (0 points)
- N/A - Did not land apply biosolids until limit was met (0 points)

3.1.3 Number of times any of the metals exceeded the ceiling limits = 0

Exceedence Points

- 0 (0 Points)
- 1 (10 Points)
- > 1 (15 Points)

3.1.4 Were biosolids land applied which exceeded the ceiling limit?

- Yes (20 Points)
- No (0 Points)

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

<p>3.1.5 If any metal limit (high quality or ceiling) was exceeded at any time, what action was taken? Has the source of the metals been identified?</p> <input type="text"/>	0
<p>6. Biosolids Storage 6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site?</p> <ul style="list-style-type: none"> <input checked="" type="radio"/> >= 180 days (0 Points) <input type="radio"/> 150 - 179 days (10 Points) <input type="radio"/> 120 - 149 days (20 Points) <input type="radio"/> 90 - 119 days (30 Points) <input type="radio"/> < 90 days (40 Points) <input type="radio"/> N/A (0 Points) <p>6.2 If you checked N/A above, explain why.</p> <input type="text"/>	0
<p>7. Issues 7.1 Describe any outstanding biosolids issues with treatment, use or overall management:</p> <input type="text"/>	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

Staffing and Preventative Maintenance (All Treatment Plants)

<p>1. Plant Staffing</p> <p>1.1 Was your wastewater treatment plant adequately staffed last year?</p> <ul style="list-style-type: none"><input type="radio"/> Yes<input checked="" type="radio"/> No <p>If No, please explain:</p> <div style="border: 1px solid black; padding: 5px;">do to recent retirement, plant staff has been down one individual since 2016 but we are in the process of hiring a new staff member in spring of 2018</div> <p>Could use more help/staff for:</p> <div style="border: 1px solid black; padding: 5px;">currently two operators plus the assistance at times from the superintendent operate the plant this is adequate for covering routine only duty's but during breakdowns or vacations the plant is under staffed.</div> <p>1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px;"></div>	
<p>2. Preventative Maintenance</p> <p>2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes (Continue with question 2)<input type="radio"/> No (40 points) <p>If No, please explain, then go to question 3:</p> <div style="border: 1px solid black; height: 20px;"></div> <p>2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No (10 points) <p>2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<ul style="list-style-type: none"><input checked="" type="radio"/> Paper file system<input type="radio"/> Computer system<input type="radio"/> Both paper and computer system<input type="radio"/> No (10 points)	0
<p>3. O&M Manual</p> <p>3.1 Does your plant have a detailed O&M and Manufacturer Equipment Manuals that can be used as a reference when needed?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No	
<p>4. Overall Maintenance /Repairs</p> <p>4.1 Rate the overall maintenance of your wastewater plant.</p> <ul style="list-style-type: none"><input type="radio"/> Excellent<input checked="" type="radio"/> Very good<input type="radio"/> Good<input type="radio"/> Fair<input type="radio"/> Poor	

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

Describe your rating:

considering that we still operate some older equipment at this facility the level of down time is very low, we also are continually replacing older less reliable equipment when ever possible.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

Operator Certification and Education

<p>1. Operator-In-Charge</p> <p>1.1 Did you have a designated operator-in-charge during the report year?</p> <p>● Yes (0 points)</p> <p>○ No (20 points)</p> <p>Name: <input style="width: 300px;" type="text" value="WILLIAM A SWENSON"/></p> <p>Certification No: <input style="width: 150px;" type="text" value="33266"/></p>	0																																																																																								
<p>2. Certification Requirements</p> <p>2.1 In accordance with Chapter NR 114.56 and 114.57, Wisconsin Administrative Code, what level and subclass(es) were required for the operator-in-charge (OIC) to operate the wastewater treatment plant and what level and subclass(es) were held by the operator-in-charge?</p> <table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2">Sub Class</th> <th rowspan="2">SubClass Description</th> <th colspan="2">WWTP</th> <th colspan="2">OIC</th> </tr> <tr> <th>Advanced</th> <th>OIT</th> <th>Basic</th> <th>Advanced</th> </tr> </thead> <tbody> <tr><td>A1</td><td>Suspended Growth Processes</td><td>X</td><td></td><td></td><td>X</td></tr> <tr><td>A2</td><td>Attached Growth Processes</td><td></td><td></td><td></td><td></td></tr> <tr><td>A3</td><td>Recirculating Media Filters</td><td></td><td></td><td></td><td></td></tr> <tr><td>A4</td><td>Ponds, Lagoons and Natural</td><td></td><td></td><td></td><td></td></tr> <tr><td>A5</td><td>Anaerobic Treatment Of Liquid</td><td></td><td></td><td></td><td></td></tr> <tr><td>B</td><td>Solids Separation</td><td>X</td><td></td><td></td><td>X</td></tr> <tr><td>C</td><td>Biological Solids/Sludges</td><td>X</td><td></td><td></td><td>X</td></tr> <tr><td>P</td><td>Total Phosphorus</td><td>X</td><td></td><td></td><td>X</td></tr> <tr><td>N</td><td>Total Nitrogen</td><td></td><td></td><td></td><td></td></tr> <tr><td>D</td><td>Disinfection</td><td>X</td><td></td><td></td><td>X</td></tr> <tr><td>L</td><td>Laboratory</td><td>X</td><td></td><td></td><td>X</td></tr> <tr><td>U</td><td>Unique Treatment Systems</td><td></td><td></td><td></td><td></td></tr> <tr><td>SS</td><td>Sanitary Sewage Collection</td><td>X</td><td>NA</td><td>NA</td><td>NA</td></tr> </tbody> </table> <p>2.2 Was the operator-in-charge certified at the appropriate level and subclass(es) to operate this plant? (Note: Certification in subclass SS, N and A5 not required in 2016; subclass SS is basic level only.)</p> <p>● Yes (0 points)</p> <p>○ No (20 points)</p>	Sub Class	SubClass Description	WWTP		OIC		Advanced	OIT	Basic	Advanced	A1	Suspended Growth Processes	X			X	A2	Attached Growth Processes					A3	Recirculating Media Filters					A4	Ponds, Lagoons and Natural					A5	Anaerobic Treatment Of Liquid					B	Solids Separation	X			X	C	Biological Solids/Sludges	X			X	P	Total Phosphorus	X			X	N	Total Nitrogen					D	Disinfection	X			X	L	Laboratory	X			X	U	Unique Treatment Systems					SS	Sanitary Sewage Collection	X	NA	NA	NA	0
Sub Class			SubClass Description	WWTP		OIC																																																																																			
	Advanced	OIT		Basic	Advanced																																																																																				
A1	Suspended Growth Processes	X			X																																																																																				
A2	Attached Growth Processes																																																																																								
A3	Recirculating Media Filters																																																																																								
A4	Ponds, Lagoons and Natural																																																																																								
A5	Anaerobic Treatment Of Liquid																																																																																								
B	Solids Separation	X			X																																																																																				
C	Biological Solids/Sludges	X			X																																																																																				
P	Total Phosphorus	X			X																																																																																				
N	Total Nitrogen																																																																																								
D	Disinfection	X			X																																																																																				
L	Laboratory	X			X																																																																																				
U	Unique Treatment Systems																																																																																								
SS	Sanitary Sewage Collection	X	NA	NA	NA																																																																																				
<p>3. Succession Planning</p> <p>3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?</p> <p><input checked="" type="checkbox"/> One or more additional certified operators on staff</p> <p><input type="checkbox"/> An arrangement with another certified operator</p> <p><input type="checkbox"/> An arrangement with another community with a certified operator</p> <p><input type="checkbox"/> An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year</p> <p><input type="checkbox"/> A consultant to serve as your certified operator</p> <p><input type="checkbox"/> None of the above (20 points)</p> <p>If "None of the above" is selected, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	0																																																																																								
<p>4. Continuing Education Credits</p>																																																																																									

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates?

OIT and Basic Certification:

- Averaging 6 or more CECs per year.
- Averaging less than 6 CECs per year.

Advanced Certification:

- Averaging 8 or more CECs per year.
- Averaging less than 8 CECs per year.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

Financial Management

<p>1. Provider of Financial Information</p> <p>Name: <input style="width: 300px;" type="text" value="Tracy Biederman"/></p> <p>Telephone: <input style="width: 150px;" type="text" value="(715)-426-3439"/> (XXX) XXX-XXXX</p> <p>E-Mail Address (optional): <input style="width: 300px;" type="text" value="tbiederman@rfcity.org"/></p>													
<p>2. Treatment Works Operating Revenues</p> <p>2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ?</p> <p><input checked="" type="radio"/> Yes (0 points)</p> <p><input type="radio"/> No (40 points)</p> <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised?</p> <p>Year: <input style="width: 100px;" type="text" value="2015"/></p> <p><input checked="" type="radio"/> 0-2 years ago (0 points)</p> <p><input type="radio"/> 3 or more years ago (20 points)</p> <p><input type="radio"/> N/A (private facility)</p> <p>2.3 Did you have a special account (e.g., CWFPP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system?</p> <p><input checked="" type="radio"/> Yes (0 points)</p> <p><input type="radio"/> No (40 points)</p>	0												
<p>REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]</p>													
<p>3. Equipment Replacement Funds</p> <p>3.1 When was the Equipment Replacement Fund last reviewed and/or revised?</p> <p>Year: <input style="width: 100px;" type="text" value="2017"/></p> <p><input checked="" type="radio"/> 1-2 years ago (0 points)</p> <p><input type="radio"/> 3 or more years ago (20 points)</p> <p><input type="radio"/> N/A</p> <p>If N/A, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>													
<p>3.2 Equipment Replacement Fund Activity</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;">3.2.1 Ending Balance Reported on Last Year's CMAR</td> <td style="width: 5%; text-align: right;">\$</td> <td style="width: 35%; text-align: right;"><input style="width: 150px;" type="text" value="408,011.46"/></td> </tr> <tr> <td>3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 150px;" type="text" value="0.00"/></td> </tr> <tr> <td>3.2.3 Adjusted January 1st Beginning Balance</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 150px;" type="text" value="408,011.46"/></td> </tr> <tr> <td>3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 150px;" type="text" value="23,565.35"/></td> </tr> </table>	3.2.1 Ending Balance Reported on Last Year's CMAR	\$	<input style="width: 150px;" type="text" value="408,011.46"/>	3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	\$	<input style="width: 150px;" type="text" value="0.00"/>	3.2.3 Adjusted January 1st Beginning Balance	\$	<input style="width: 150px;" type="text" value="408,011.46"/>	3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	\$	<input style="width: 150px;" type="text" value="23,565.35"/>	
3.2.1 Ending Balance Reported on Last Year's CMAR	\$	<input style="width: 150px;" type="text" value="408,011.46"/>											
3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	\$	<input style="width: 150px;" type="text" value="0.00"/>											
3.2.3 Adjusted January 1st Beginning Balance	\$	<input style="width: 150px;" type="text" value="408,011.46"/>											
3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	\$	<input style="width: 150px;" type="text" value="23,565.35"/>											

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*) -

\$ 0.00

3.2.6 Ending Balance as of December 31st for CMAR Reporting Year

\$ 431,576.81

All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.

3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.

3.3 What amount should be in your Replacement Fund?

\$ 418,600.00

0

Please note: If you had a CWFPP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the SectionInstructions link under Info header in the left-side menu.

3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?

- Yes
- No

If No, please explain.

4. Future Planning

4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?

- Yes - If Yes, please provide major project information, if not already listed below.
- No

Project #	Project Description	Estimated Cost	Approximate Construction Year
1	Sanitary Sewer Pipe Lining - This is an ongoing budget item to maintain an annual sewer slip lining program. This will improve the performance and extend the useful life of our existing collection system.	160000	2018
2	Collection System Replacements - We are budgeting annually for ongoing sewer pipe replacements that are not able to be rehabilitated by slip lining. This will be an annual maintenance program for our system maintenance and adjusted for inflation. This also covers monform repair of manholes.	59500	2018
3	Rehabilitate north sewer interceptor and eliminate north main lift station.	4100000	2019
4	Remove South Main lift station and run area by gravity to Spring Creek lift station.	135500	2020
5	Fine Screening WWTP influent.	155000	2019
6	New fine bubble aeration and mixers to replace current rotors in oxidation ditch. It will increase the design loading of the ditch and result in an energy savings.	710000	2020
7	Replace chlorine disinfection with UV.	550000	2025

5. Financial Management General Comments

ENERGY EFFICIENCY AND USE

6. Collection System

6.1 Energy Usage

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

6.1.1 Enter the monthly energy usage from the different energy sources:

COLLECTION SYSTEM PUMPAGE: Total Power Consumed

Number of Municipally Owned Pump/Lift Stations:

	Electricity Consumed (kWh)	Natural Gas Consumed (therms)
January	2,993	
February	3,693	
March	4,142	
April	3,960	
May	3,516	
June	3,253	
July	3,306	
August	4,573	
September	3,696	
October	3,641	
November	3,705	
December	4,082	
Total	44,560	0
Average	3,713	0

6.1.2 Comments:

6.2 Energy Related Processes and Equipment

6.2.1 Indicate equipment and practices utilized at your pump/lift stations (Check all that apply):

- Comminution or Screening
- Extended Shaft Pumps
- Flow Metering and Recording
- Pneumatic Pumping
- SCADA System
- Self-Priming Pumps
- Submersible Pumps
- Variable Speed Drives
- Other:

6.2.2 Comments:

6.3 Has an Energy Study been performed for your pump/lift stations?

- No
- Yes

Year:

By Whom:

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

Describe and Comment:

6.4 Future Energy Related Equipment

6.4.1 What energy efficient equipment or practices do you have planned for the future for your pump/lift stations?

We plan on eliminating 2 lift Stations in the next couple of years. All the flow currently being pumped through North Main lift will flow by gravity all the way to the WWTP.

7. Treatment Facility

7.1 Energy Usage

7.1.1 Enter the monthly energy usage from the different energy sources:

TREATMENT PLANT: Total Power Consumed/Month

	Electricity Consumed (kWh)	Total Influent Flow (MG)	Electricity Consumed/Flow (kWh/MG)	Total Influent BOD (1000 lbs)	Electricity Consumed/Total Influent BOD (kWh/1000lbs)	Natural Gas Consumed (therms)
January	128,905	37.46	3,441	83.36	1,546	7,134
February	132,584	35.32	3,754	78.06	1,698	5,127
March	123,420	37.97	3,250	85.59	1,442	5,140
April	123,544	37.97	3,254	86.10	1,435	2,494
May	121,522	42.52	2,858	79.42	1,530	479
June	123,514	39.17	3,153	73.05	1,691	24
July	103,457	38.69	2,674	75.61	1,368	26
August	102,771	37.73	2,724	75.58	1,360	25
September	102,929	39.14	2,630	86.76	1,186	27
October	113,129	41.25	2,743	94.15	1,202	338
November	112,921	38.67	2,920	94.44	1,196	2,031
December	116,813	38.83	3,008	97.65	1,196	4,886
Total	1,405,509	464.72		1,009.77		27,731
Average	117,126	38.73	3,034	84.15	1,404	2,311

7.1.2 Comments:

We have had a substantial decrease in electrical usage with our new bio-solids facility. We were able to cut horsepower and reduce our peak loading.

7.2 Energy Related Processes and Equipment

7.2.1 Indicate equipment and practices utilized at your treatment facility (Check all that apply):

- Aerobic Digestion
- Anaerobic Digestion
- Biological Phosphorus Removal
- Coarse Bubble Diffusers
- Dissolved O2 Monitoring and Aeration Control
- Effluent Pumping
- Fine Bubble Diffusers
- Influent Pumping

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

Mechanical Sludge Processing

Nitrification

SCADA System

UV Disinfection

Variable Speed Drives

Other:

7.2.2 Comments:

7.3 Future Energy Related Equipment

7.3.1 What energy efficient equipment or practices do you have planned for the future for your treatment facility?

We are installing fine bubble aeration to replace the current mechanical aeration on the oxidation ditches. Peak horsepower per ditch will be reduced from 120 to 55.

8. Biogas Generation

8.1 Do you generate/produce biogas at your facility?

No

Yes

If Yes, how is the biogas used (Check all that apply):

Flared Off

Building Heat

Process Heat

Generate Electricity

Other:

9. Energy Efficiency Study

9.1 Has an Energy Study been performed for your treatment facility?

No

Yes

Entire facility

Year:

By Whom:

Describe and Comment:

Part of the facility

Year:

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

By Whom:

Focus on Energy and Strand engineering

Describe and Comment:

We are looking at fine bubble aeration and mixers to replace the current rotor system. Peak Hp will go from 120 to 55 per ditch. The blower for the diffusers will be controlled by VFD that receives a signal from a DO analyzer.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

Sanitary Sewer Collection Systems

1. Capacity, Management, Operation, and Maintenance (CMOM) Program

1.1 Do you have a CMOM program that is being implemented?

- Yes
- No

If No, explain:

1.2 Do you have a CMOM program that contains all the applicable components and items according to Wisc. Adm Code NR 210.23 (4)?

- Yes
- No (30 points)
- N/A

If No or N/A, explain:

1.3 Does your CMOM program contain the following components and items? (check the components and items that apply)

- Goals [NR 210.23 (4)(a)]

Describe the major goals you had for your collection system last year:

1. Continue training personnel of the use of the Vactor truck and sewer televising equipment.
2. Clean 25% of the collection system.
3. Televis 5% of the collection system.
4. Inspect 5% of system manholes.
5. Revise manhole inspection form.

Did you accomplish them?

- Yes
- No

If No, explain:

We came up short of our goal on cleaning and televising. We had an employee out for 2.5 months in 2017. Our camera was in for repair during the summer of 2017. We are fully staffed this year and should be able to dedicate considerably more time to cleaning and televising.

- Organization [NR 210.23 (4) (b)]

Does this chapter of your CMOM include:

- Organizational structure and positions (eg. organizational chart and position descriptions)
- Internal and external lines of communication responsibilities
- Person(s) responsible for reporting overflow events to the department and the public

- Legal Authority [NR 210.23 (4) (c)]

What is the legally binding document that regulates the use of your sewer system?

sewer use ordinance

If you have a Sewer Use Ordinance or other similar document, when was it last reviewed and revised? (MM/DD/YYYY) 06/14/2016

Does your sewer use ordinance or other legally binding document address the following:

- Private property inflow and infiltration
- New sewer and building sewer design, construction, installation, testing and inspection
- Rehabilitated sewer and lift station installation, testing and inspection
- Sewage flows satellite system and large private users are monitored and controlled, as necessary
- Fat, oil and grease control
- Enforcement procedures for sewer use non-compliance

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

Operation and Maintenance [NR 210.23 (4) (d)]
Does your operation and maintenance program and equipment include the following:

- Equipment and replacement part inventories
- Up-to-date sewer system map
- A management system (computer database and/or file system) for collection system information for O&M activities, investigation and rehabilitation
- A description of routine operation and maintenance activities (see question 2 below)
- Capacity assessment program
- Basement back assessment and correction
- Regular O&M training

Design and Performance Provisions [NR 210.23 (4) (e)]
What standards and procedures are established for the design, construction, and inspection of the sewer collection system, including building sewers and interceptor sewers on private property?

- State Plumbing Code, DNR NR 110 Standards and/or local Municipal Code Requirements
- Construction, Inspection, and Testing
- Others:

Overflow Emergency Response Plan [NR 210.23 (4) (f)]
Does your emergency response capability include:

- Responsible personnel communication procedures
- Response order, timing and clean-up
- Public notification protocols
- Training
- Emergency operation protocols and implementation procedures

Annual Self-Auditing of your CMOM Program [NR 210.23 (5)]

Special Studies Last Year (check only those that apply):

- Infiltration/Inflow (I/I) Analysis
- Sewer System Evaluation Survey (SSES)
- Sewer Evaluation and Capacity Management Plan (SECAP)
- Lift Station Evaluation Report
- Others:

0

2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning	15	% of system/year
Root removal	5	% of system/year
Flow monitoring	1	% of system/year
Smoke testing	0	% of system/year
Sewer line televising	3	% of system/year
Manhole inspections	10	% of system/year
Lift station O&M	12	# per L.S./year
Manhole rehabilitation	1.25	% of manholes rehabbed
Mainline rehabilitation		

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

Private sewer inspections	<input type="text" value="1"/>	% of sewer lines rehabbed
Private sewer I/I removal	<input type="text" value="0"/>	% of system/year
River or water crossings	<input type="text" value="0"/>	% of pipe crossings evaluated or maintained

Please include additional comments about your sanitary sewer collection system below:

We are continuing our program to line clay sewers and rehab old man holes. We rate our sewer lines 1-5 with 5 being the worse. In 2018 we will have all known sewers remaining with a 5 rating lined.

3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

<input type="text" value="32.35"/>	Total actual amount of precipitation last year in inches
<input type="text" value="30.74"/>	Annual average precipitation (for your location)
<input type="text" value="63"/>	Miles of sanitary sewer
<input type="text" value="5"/>	Number of lift stations
<input type="text" value="0"/>	Number of lift station failures
<input type="text" value="0"/>	Number of sewer pipe failures
<input type="text" value="2"/>	Number of basement backup occurrences
<input type="text" value="4"/>	Number of complaints
<input type="text"/>	Average daily flow in MGD (if available)
<input type="text"/>	Peak monthly flow in MGD (if available)
<input type="text"/>	Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

<input type="text" value="0.00"/>	Lift station failures (failures/year)
<input type="text" value="0.00"/>	Sewer pipe failures (pipe failures/sewer mile/yr)
<input type="text" value="0.03"/>	Sanitary sewer overflows (number/sewer mile/yr)
<input type="text" value="0.03"/>	Basement backups (number/sewer mile)
<input type="text" value="0.06"/>	Complaints (number/sewer mile)
<input type="text"/>	Peaking factor ratio (Peak Monthly: Annual Daily Avg)
<input type="text"/>	Peaking factor ratio (Peak Hourly: Annual Daily Avg)

4. Overflows

LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OFERFLOWS REPORTED **				
	Date	Location	Cause	Estimated Volume (MG)
0	8/29/2017 9: 45: 00 AM - 8/29/2017 9: 45: 00 AM	TFO Event - Bio-solids storage at WWTP, less than 100 gallons, 423 S. Apollo Rd	Equipment Failure	0.0001 - 0.0001
1	12/12/2017 5: 30: 00 PM - 12/12/2017 6: 30: 00 PM	2555 Prairie Drive; MH# 804	Plugged Sewer	0.0001 - 0.0001

** If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

<p>What actions were taken, or are underway, to reduce or eliminate SSO or TFO occurrences in the future?</p> <div style="border: 1px solid black; padding: 5px; margin-bottom: 5px;"> <p>1. The TFO was due to a contractor hose failure. We are looking at increasing the size of the concrete pad where trucks load bio-solids to contain any future spills.</p> <p>2. We worked with the industry that was discharging material causing the SSO. We had a similar incident in the spring of 2018 but believe we have the situation resolved. Screening had been removed from floor drains in the facility which caught the debris. The screens have been reinstalled and we continue to monitor.</p> </div>	
<p>5. Infiltration / Inflow (I/I)</p> <p>5.1 Was infiltration/inflow (I/I) significant in your community last year?</p> <p><input type="radio"/> Yes</p> <p><input checked="" type="radio"/> No</p> <p>If Yes, please describe:</p> <div style="border: 1px solid black; height: 20px; margin-bottom: 5px;"></div> <p>5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?</p> <p><input type="radio"/> Yes</p> <p><input checked="" type="radio"/> No</p> <p>If Yes, please describe:</p> <div style="border: 1px solid black; height: 20px; margin-bottom: 5px;"></div> <p>5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:</p> <div style="border: 1px solid black; padding: 2px; margin-bottom: 5px;"> <p>Fairly stable. Lining and manhole rehab program has slowed the inflow.</p> </div> <p>5.4 What is being done to address infiltration/inflow in your collection system?</p> <div style="border: 1px solid black; padding: 2px; margin-bottom: 5px;"> <p>We continue to reduce our inflow with the lining and manhole rehab program.</p> </div>	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

Grading Summary

WPDES No: 0029394

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	B	3	3	9
BOD/CBOD	A	4	10	40
TSS	A	4	5	20
Ammonia	A	4	5	20
Phosphorus	A	4	3	12
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			37	145
GRADE POINT AVERAGE (GPA) = 3.92				

Notes:

A = Voluntary Range (Response Optional)

B = Voluntary Range (Response Optional)

C = Recommendation Range (Response Required)

D = Action Range (Response Required)

F = Action Range (Response Required)

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2018 2017

Resolution or Owner's Statement

Name of Governing
Body or Owner:

Date of Resolution or
Action Taken:

Resolution Number:

Date of Submittal:

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR
SECTIONS (Optional for grade A or B. Required for grade C, D, or F):

Influent Flow and Loadings: Grade = B

Effluent Quality: BOD: Grade = A

Effluent Quality: TSS: Grade = A

Effluent Quality: Ammonia: Grade = A

Effluent Quality: Phosphorus: Grade = A

Biosolids Quality and Management: Grade = A

Staffing: Grade = A

Operator Certification: Grade = A

Financial Management: Grade = A

Collection Systems: Grade = A

(Regardless of grade, response required for Collection Systems if SSOs were reported)

We had one SSO caused by an industry discharging material to the sanitary sewer system that caused a blockage. We reviewed the process with representatives from the business and found screens over the drain that were not in place. Since the screens were replaced we have televised the line 2 times and the material is no longer entering the sewer.

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL
GRADE POINT AVERAGE AND ANY GENERAL COMMENTS

(Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)

G.P.A. = 3.92