

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

Influent Flow and Loading

1. Monthly Average Flows and (C)BOD Loadings

1.1 Verify the following monthly flows and (C)BOD loadings to your facility.

Influent No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average (C)BOD Concentration mg/L	x	8.34	=	Influent Monthly Average (C)BOD Loading, lbs/day
January	1.2164	x	296	x	8.34	=	3,004
February	1.2516	x	322	x	8.34	=	3,357
March	1.2392	x	296	x	8.34	=	3,064
April	1.2961	x	296	x	8.34	=	3,199
May	1.2480	x	279	x	8.34	=	2,907
June	1.2405	x	250	x	8.34	=	2,588
July	1.2415	x	269	x	8.34	=	2,787
August	1.2361	x	246	x	8.34	=	2,541
September	1.3657	x	263	x	8.34	=	2,992
October	1.3745	x	291	x	8.34	=	3,332
November	1.3204	x	278	x	8.34	=	3,063
December	1.2741	x	269	x	8.34	=	2,856

2. Maximum Monthly Design Flow and Design (C)BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	1.824	x	90	=	1.6416
		x	100	=	1.824
Design (C)BOD, lbs/day	3152	x	90	=	2836.8
		x	100	=	3152

2.2 Verify the number of times the flow and (C)BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times (C)BOD was greater than 90% of design	Number of times (C)BOD was greater than 100% of design
January	1	0	0	1	0
February	1	0	0	1	1
March	1	0	0	1	0
April	1	0	0	1	1
May	1	0	0	1	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	1	0
October	1	0	0	1	1
November	1	0	0	1	0
December	1	0	0	1	0
Points per each		2	1	3	2
Exceedances		0	0	9	3
Points		0	0	27	6
Total Number of Points					33

33

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?
● Yes Enter last calibration date (MM/DD/YYYY)

2018-03-15

○ No

If No, please explain:

4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

● Yes

○ No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

○ Yes

● No

If Yes, please explain:

5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks

Holding Tanks

Grease Traps

○ Yes

● Yes

● Yes

● No

○ No

○ No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

○ Yes

0

gallons

● No

Holding Tanks

● Yes

33800

gallons

○ No

Grease Traps

● Yes

13000

gallons

○ No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

no effect on daily treatment

6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

○ Yes

● No

If yes, describe the situation and your community's response.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

<p><input checked="" type="radio"/> Yes <input type="radio"/> No</p> <p>If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.</p> <p>machine shop holding tanks , solids were settled out prior to being fed into head of plant. 400 gallon loads hauled quarterly.</p>	
---	--

Total Points Generated	33
Score (100 - Total Points Generated)	67
Section Grade	D

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

Effluent Quality and Plant Performance (BOD/CBOD)

1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	7	1	0	0
February	30	27	8	1	0	0
March	30	27	5	1	0	0
April	30	27	6	1	0	0
May	30	27	7	1	0	0
June	30	27	5	1	0	0
July	30	27	3	1	0	0
August	30	27	2	1	0	0
September	30	27	3	1	0	0
October	30	27	6	1	0	0
November	30	27	6	1	0	0
December	30	27	6	1	0	0

* Equals limit if limit is <= 10

Months of discharge/yr	12		
Points per each exceedance with 12 months of discharge		7	3
Exceedances		0	0
Points		0	0
Total number of points			0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

- Yes

Enter last calibration date (MM/DD/YYYY)

- No

If No, please explain:

3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

- Yes

- No

0

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

<p>If Yes, please explain:</p> <div style="border: 1px solid black; padding: 2px;">Permit exceedance for residual chlorine due to equipment malfunction</div> <p>4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?</p> <p><input type="radio"/> Yes</p> <p><input checked="" type="radio"/> No</p> <p>If Yes, please explain:</p> <div style="border: 1px solid black; height: 20px;"></div> <p>4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?</p> <p><input type="radio"/> Yes</p> <p><input type="radio"/> No</p> <p><input checked="" type="radio"/> N/A</p> <p>Please explain unless not applicable:</p> <div style="border: 1px solid black; height: 20px;"></div>

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

Effluent Quality and Plant Performance (Total Suspended Solids)

1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	5	1	0	0
February	30	27	5	1	0	0
March	30	27	3	1	0	0
April	30	27	3	1	0	0
May	30	27	4	1	0	0
June	30	27	3	1	0	0
July	30	27	3	1	0	0
August	30	27	2	1	0	0
September	30	27	3	1	0	0
October	30	27	2	1	0	0
November	30	27	3	1	0	0
December	30	27	3	1	0	0

* Equals limit if limit is <= 10

Months of Discharge/yr	12		
Points per each exceedance with 12 months of discharge:	7	3	
Exceedances	0	0	
Points	0	0	
Total Number of Points		0	

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

Effluent Quality and Plant Performance (Ammonia - NH3)

1. Effluent Ammonia Results

1.1 Verify the following monthly and weekly average effluent values, exceedances and points for ammonia

Outfall No. 001	Monthly Average NH3 Limit (mg/L)	Weekly Average NH3 Limit (mg/L)	Effluent Monthly Average NH3 (mg/L)	Monthly Permit Limit Exceedance	Effluent Weekly Average for Week 1	Effluent Weekly Average for Week 2	Effluent Weekly Average for Week 3	Effluent Weekly Average for Week 4	Weekly Permit Limit Exceedance
January	5.7		1.1215384	62 0					
February	5.7		.42808333	33 0					
March	5.7		.1	0					
April	5.7		.24342857	1 0					
May		2			.20466666	.79966666	.08633333	.30933333	33
June		2			.10333333	.07333333	.30733333	.30933333	33
July		2			.09	.1	.12666666	.17533333	33
August		2			.11333333	.11333333	.10666666	.12	
September		2			.1	.14333333	.15333333	.18666666	7
October		2			.53	1.09666666	1.28	.89666666	7
November	5.7		.61228571	14 0					
December	5.7		.36666666	7 0					
Points per each exceedance of Monthly average:									10
Exceedances, Monthly:									0
Points:									0
Points per each exceedance of weekly average (when there is no monthly average):									2.5
Exceedances, Weekly:									0
Points:									0
Total Number of Points									0

NOTE: Limit exceedances are considered for monthly OR weekly averages but not both. When a monthly average limit exists it will be used to determine exceedances and generate points. This will be true even if a weekly limit also exists. When a weekly average limit exists and a monthly limit does not exist, the weekly limit will be used to determine exceedances and generate points.

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

Effluent Quality and Plant Performance (Phosphorus)

1. Effluent Phosphorus Results

1.1 Verify the following monthly average effluent values, exceedances, and points for Phosphorus

Outfall No. 001	Monthly Average phosphorus Limit (mg/L)	Effluent Monthly Average phosphorus (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	1.5	0.212	1	0
February	1.5	0.199	1	0
March	1.5	0.156	1	0
April	1.5	0.176	1	0
May	1.5	0.738	1	0
June	1.5	0.204	1	0
July	1.5	0.232	1	0
August	1.5	0.142	1	0
September	1.5	0.233	1	0
October	1.5	0.129	1	0
November	1.5	0.141	1	0
December	1.5	0.140	1	0
Months of Discharge/yr			12	
Points per each exceedance with 12 months of discharge:				10
Exceedances				0
Total Number of Points				0

0

NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

Biosolids Quality and Management

1. Biosolids Use/Disposal

1.1 How did you use or dispose of your biosolids? (Check all that apply)

- Land applied under your permit
- Publicly Distributed Exceptional Quality Biosolids
- Hauled to another permitted facility
- Landfilled
- Incinerated
- Other

NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.

1.1.1 If you checked Other, please describe:

3. Biosolids Metals

Number of biosolids outfalls in your WPDES permit:

3.1 For each outfall tested, verify the biosolids metal quality values for your facility during the last calendar year.

Outfall No. 002 - SLUDGE TO WCWBF

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75											<2.8			0	0
Cadmium		39	85											.6			0	0
Copper		1500	4300											320			0	0
Lead		300	840											5			0	0
Mercury		17	57											7.2			0	0
Molybdenum	60		75											7	0			0
Nickel	336		420											17	0			0
Selenium	80		100											<6.8	0			0
Zinc		2800	7500											450			0	0

3.1.1 Number of times any of the metals exceeded the high quality limits OR 80% of the limit for molybdenum, nickel, or selenium = 0

Exceedence Points

- 0 (0 Points)
- 1-2 (10 Points)
- > 2 (15 Points)

3.1.2 If you exceeded the high quality limits, did you cumulatively track the metals loading at each land application site? (check applicable box)

- Yes
- No (10 points)
- N/A - Did not exceed limits or no HQ limit applies (0 points)
- N/A - Did not land apply biosolids until limit was met (0 points)

3.1.3 Number of times any of the metals exceeded the ceiling limits = 0

Exceedence Points

- 0 (0 Points)
- 1 (10 Points)
- > 1 (15 Points)

3.1.4 Were biosolids land applied which exceeded the ceiling limit?

- Yes (20 Points)
- No (0 Points)

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

<p>3.1.5 If any metal limit (high quality or ceiling) was exceeded at any time, what action was taken? Has the source of the metals been identified?</p> <input type="text"/>	0
<p>6. Biosolids Storage 6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site? <ul style="list-style-type: none"> ● <input type="radio"/> >= 180 days (0 Points) ○ <input type="radio"/> 150 - 179 days (10 Points) ○ <input type="radio"/> 120 - 149 days (20 Points) ○ <input type="radio"/> 90 - 119 days (30 Points) ○ <input type="radio"/> < 90 days (40 Points) ○ <input type="radio"/> N/A (0 Points) 6.2 If you checked N/A above, explain why.</p> <input type="text"/>	0
<p>7. Issues 7.1 Describe any outstanding biosolids issues with treatment, use or overall management:</p> <input type="text"/>	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

Staffing and Preventative Maintenance (All Treatment Plants)

<p>1. Plant Staffing</p> <p>1.1 Was your wastewater treatment plant adequately staffed last year?</p> <ul style="list-style-type: none">● Yes○ No <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>Could use more help/staff for:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?</p> <ul style="list-style-type: none">● Yes○ No <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	
<p>2. Preventative Maintenance</p> <p>2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?</p> <ul style="list-style-type: none">● Yes (Continue with question 2) <input type="checkbox"/><input type="checkbox"/>○ No (40 points) <input type="checkbox"/><input type="checkbox"/> <p>If No, please explain, then go to question 3:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?</p> <ul style="list-style-type: none">● Yes○ No (10 points) <p>2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?</p> <ul style="list-style-type: none">● Yes<ul style="list-style-type: none">● Paper file system○ Computer system○ Both paper and computer system○ No (10 points)	0
<p>3. O&M Manual</p> <p>3.1 Does your plant have a detailed O&M and Manufacturer Equipment Manuals that can be used as a reference when needed?</p> <ul style="list-style-type: none">● Yes○ No	
<p>4. Overall Maintenance /Repairs</p> <p>4.1 Rate the overall maintenance of your wastewater plant.</p> <ul style="list-style-type: none">○ Excellent● Very good○ Good○ Fair○ Poor <p>Describe your rating:</p>	

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

Staff has done a good job with the manufactures recommendations on equipment maintenance. Maintenance schedules are followed and older equipment is replaced when needed.	
---	--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

Operator Certification and Education

<p>1. Operator-In-Charge</p> <p>1.1 Did you have a designated operator-in-charge during the report year?</p> <ul style="list-style-type: none"> ● Yes (0 points) ○ No (20 points) <p>Name: <input style="width: 300px;" type="text" value="WILLIAM A SWENSON"/></p> <p>Certification No: <input style="width: 150px;" type="text" value="33266"/></p>	0																																																																																								
<p>2. Certification Requirements</p> <p>2.1 In accordance with Chapter NR 114.56 and 114.57, Wisconsin Administrative Code, what level and subclass(es) were required for the operator-in-charge (OIC) to operate the wastewater treatment plant and what level and subclass(es) were held by the operator-in-charge?</p> <table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 10px;"> <thead> <tr> <th rowspan="2">Sub Class</th> <th rowspan="2">SubClass Description</th> <th colspan="2">WWTP</th> <th colspan="2">OIC</th> </tr> <tr> <th>Advanced</th> <th>OIT</th> <th>Basic</th> <th>Advanced</th> </tr> </thead> <tbody> <tr><td>A1</td><td>Suspended Growth Processes</td><td style="text-align: center;">X</td><td></td><td></td><td style="text-align: center;">X</td></tr> <tr><td>A2</td><td>Attached Growth Processes</td><td></td><td></td><td></td><td></td></tr> <tr><td>A3</td><td>Recirculating Media Filters</td><td></td><td></td><td></td><td></td></tr> <tr><td>A4</td><td>Ponds, Lagoons and Natural</td><td></td><td></td><td></td><td></td></tr> <tr><td>A5</td><td>Anaerobic Treatment Of Liquid</td><td></td><td></td><td></td><td></td></tr> <tr><td>B</td><td>Solids Separation</td><td style="text-align: center;">X</td><td></td><td></td><td style="text-align: center;">X</td></tr> <tr><td>C</td><td>Biological Solids/Sludges</td><td style="text-align: center;">X</td><td></td><td></td><td style="text-align: center;">X</td></tr> <tr><td>P</td><td>Total Phosphorus</td><td style="text-align: center;">X</td><td></td><td></td><td style="text-align: center;">X</td></tr> <tr><td>N</td><td>Total Nitrogen</td><td></td><td></td><td></td><td></td></tr> <tr><td>D</td><td>Disinfection</td><td style="text-align: center;">X</td><td></td><td></td><td style="text-align: center;">X</td></tr> <tr><td>L</td><td>Laboratory</td><td style="text-align: center;">X</td><td></td><td></td><td style="text-align: center;">X</td></tr> <tr><td>U</td><td>Unique Treatment Systems</td><td></td><td></td><td></td><td></td></tr> <tr><td>SS</td><td>Sanitary Sewage Collection</td><td style="text-align: center;">X</td><td style="text-align: center;">NA</td><td style="text-align: center;">NA</td><td style="text-align: center;">NA</td></tr> </tbody> </table> <p>2.2 Was the operator-in-charge certified at the appropriate level and subclass(es) to operate this plant? (Note: Certification in subclass SS, N and A5 not required in 2018; subclass SS is basic level only.)</p> <ul style="list-style-type: none"> ● Yes (0 points) ○ No (20 points) 	Sub Class	SubClass Description	WWTP		OIC		Advanced	OIT	Basic	Advanced	A1	Suspended Growth Processes	X			X	A2	Attached Growth Processes					A3	Recirculating Media Filters					A4	Ponds, Lagoons and Natural					A5	Anaerobic Treatment Of Liquid					B	Solids Separation	X			X	C	Biological Solids/Sludges	X			X	P	Total Phosphorus	X			X	N	Total Nitrogen					D	Disinfection	X			X	L	Laboratory	X			X	U	Unique Treatment Systems					SS	Sanitary Sewage Collection	X	NA	NA	NA	0
Sub Class			SubClass Description	WWTP		OIC																																																																																			
	Advanced	OIT		Basic	Advanced																																																																																				
A1	Suspended Growth Processes	X			X																																																																																				
A2	Attached Growth Processes																																																																																								
A3	Recirculating Media Filters																																																																																								
A4	Ponds, Lagoons and Natural																																																																																								
A5	Anaerobic Treatment Of Liquid																																																																																								
B	Solids Separation	X			X																																																																																				
C	Biological Solids/Sludges	X			X																																																																																				
P	Total Phosphorus	X			X																																																																																				
N	Total Nitrogen																																																																																								
D	Disinfection	X			X																																																																																				
L	Laboratory	X			X																																																																																				
U	Unique Treatment Systems																																																																																								
SS	Sanitary Sewage Collection	X	NA	NA	NA																																																																																				
<p>3. Succession Planning</p> <p>3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?</p> <ul style="list-style-type: none"> <input checked="" type="checkbox"/> One or more additional certified operators on staff <input type="checkbox"/> An arrangement with another certified operator <input type="checkbox"/> An arrangement with another community with a certified operator <input type="checkbox"/> An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year <input type="checkbox"/> A consultant to serve as your certified operator <input type="checkbox"/> None of the above (20 points) <p>If "None of the above" is selected, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%; margin-top: 5px;"></div>	0																																																																																								
<p>4. Continuing Education Credits</p>																																																																																									

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates?

OIT and Basic Certification:

- Averaging 6 or more CECs per year.
- Averaging less than 6 CECs per year.

Advanced Certification:

- Averaging 8 or more CECs per year.
- Averaging less than 8 CECs per year.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

Financial Management

<p>1. Provider of Financial Information</p> <p>Name: <input style="width: 150px;" type="text" value="Sarah Karlsson"/></p> <p>Telephone: <input style="width: 150px;" type="text" value="(715)-426-3449"/> (XXX) XXX-XXXX</p> <p>E-Mail Address (optional): <input style="width: 300px;" type="text" value="skarlsson@rfcity.org"/></p>																	
<p>2. Treatment Works Operating Revenues</p> <p>2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ?</p> <p>● Yes (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ No (40 points)</p> <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised?</p> <p>Year: <input style="width: 100px;" type="text" value="2016"/></p> <p>● 0-2 years ago (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ 3 or more years ago (20 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ N/A (private facility)</p> <p>2.3 Did you have a special account (e.g., CWFPP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system?</p> <p>● Yes (0 points)</p> <p>○ No (40 points)</p>	0																
<p>REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]</p>																	
<p>3. Equipment Replacement Funds</p> <p>3.1 When was the Equipment Replacement Fund last reviewed and/or revised?</p> <p>Year: <input style="width: 100px;" type="text" value="2018"/></p> <p>● 1-2 years ago (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ 3 or more years ago (20 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ N/A</p> <p>If N/A, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>																	
<p>3.2 Equipment Replacement Fund Activity</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;">3.2.1 Ending Balance Reported on Last Year's CMAR</td> <td style="width: 5%;"></td> <td style="width: 5%; text-align: right;">\$</td> <td style="width: 30%; text-align: right;"><input style="width: 100%;" type="text" value="431,576.81"/></td> </tr> <tr> <td>3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)</td> <td style="text-align: center;">+</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="8,194.09"/></td> </tr> <tr> <td>3.2.3 Adjusted January 1st Beginning Balance</td> <td></td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="439,770.90"/></td> </tr> <tr> <td>3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)</td> <td style="text-align: center;">+</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="0.00"/></td> </tr> </table>	3.2.1 Ending Balance Reported on Last Year's CMAR		\$	<input style="width: 100%;" type="text" value="431,576.81"/>	3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	+	\$	<input style="width: 100%;" type="text" value="8,194.09"/>	3.2.3 Adjusted January 1st Beginning Balance		\$	<input style="width: 100%;" type="text" value="439,770.90"/>	3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+	\$	<input style="width: 100%;" type="text" value="0.00"/>	
3.2.1 Ending Balance Reported on Last Year's CMAR		\$	<input style="width: 100%;" type="text" value="431,576.81"/>														
3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	+	\$	<input style="width: 100%;" type="text" value="8,194.09"/>														
3.2.3 Adjusted January 1st Beginning Balance		\$	<input style="width: 100%;" type="text" value="439,770.90"/>														
3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+	\$	<input style="width: 100%;" type="text" value="0.00"/>														

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*) -

\$ 0.00

3.2.6 Ending Balance as of December 31st for CMAR Reporting Year

\$ 439,770.90

All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.

3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.

3.3 What amount should be in your Replacement Fund?

\$ 895.00

Please note: If you had a CFWP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the SectionInstructions link under Info header in the left-side menu.

0

3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?

- Yes
- No

If No, please explain.

The waste treatment plant added a new sludge building and retired the old sludge mixing system. These changes were capitalized in 2018. This change in value will be funded in 2019 as cash flows allow and subsequently until fully funded.

4. Future Planning

4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?

- Yes - If Yes, please provide major project information, if not already listed below.
- No

Project #	Project Description	Estimated Cost	Approximate Construction Year
1	Sanitary Sewer Pipe Lining - This is an ongoing budget item to maintain an annual sewer slip lining program. This will improve the performance and extend the useful life of our existing collection system.	160000	2019
2	Collection System Replacements - We are budgeting annually for ongoing sewer pipe replacements that are not able to be rehabilitated by slip lining. This will be an annual maintenance program for our system maintenance and adjusted for inflation. This also covers monform repair of manholes.	59500	2019
3	Rehabilitate north sewer interceptor and eliminate north main lift station.	4100000	2020
4	Remove South Main lift station and run area by gravity to Spring Creek lift station.	135500	2020
5	Fine Screening WWTP influent.	155000	2020
6	New fine bubble aeration and mixers to replace current rotors in oxidation ditch. It will increase the design loading of the ditch and result in an energy savings.	710000	2020
7	Replace chlorine disinfection with UV.	550000	2025

5. Financial Management General Comments

Financial information is reviewed monthly with Utilities Advisory Board; as well as during bi-annual budgeting process.

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

ENERGY EFFICIENCY AND USE

6. Collection System

6.1 Energy Usage

6.1.1 Enter the monthly energy usage from the different energy sources:

COLLECTION SYSTEM PUMPAGE: Total Power Consumed

Number of Municipally Owned Pump/Lift Stations:

	Electricity Consumed (kWh)	Natural Gas Consumed (therms)
January	4,957	
February	5,170	
March	7,244	
April	7,382	
May	7,260	
June	5,829	
July	5,232	
August	5,599	
September	5,007	
October	5,201	
November	5,118	
December	5,151	
Total	69,150	0
Average	5,763	0

6.1.2 Comments:

6.2 Energy Related Processes and Equipment

6.2.1 Indicate equipment and practices utilized at your pump/lift stations (Check all that apply):

- Comminution or Screening
- Extended Shaft Pumps
- Flow Metering and Recording
- Pneumatic Pumping
- SCADA System
- Self-Priming Pumps
- Submersible Pumps
- Variable Speed Drives
- Other:

6.2.2 Comments:

6.3 Has an Energy Study been performed for your pump/lift stations?

- No
- Yes

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

Year:

By Whom:

Describe and Comment:

6.4 Future Energy Related Equipment

6.4.1 What energy efficient equipment or practices do you have planned for the future for your pump/lift stations?

The plan is eliminating 2 lift stations by 2021. When our North Main Lift is eliminated all the flow being pumped now will be gravity to the WWTP. The lift accounted for 18963 kWh in 2018.

7. Treatment Facility

7.1 Energy Usage

7.1.1 Enter the monthly energy usage from the different energy sources:

TREATMENT PLANT: Total Power Consumed/Month

	Electricity Consumed (kWh)	Total Influent Flow (MG)	Electricity Consumed/Flow (kWh/MG)	Total Influent BOD (1000 lbs)	Electricity Consumed/Total Influent BOD (kWh/1000lbs)	Natural Gas Consumed (therms)
January	107,515	37.71	2,851	93.12	1,155	5,033
February	118,600	35.04	3,385	94.00	1,262	4,802
March	110,765	38.42	2,883	94.98	1,166	3,076
April	125,904	38.88	3,238	95.97	1,312	3,629
May	121,546	38.69	3,142	90.12	1,349	181
June	118,179	37.22	3,175	77.64	1,522	25
July	120,824	38.49	3,139	86.40	1,398	16
August	125,919	38.32	3,286	78.77	1,599	0
September	127,627	40.97	3,115	89.76	1,422	27
October	112,062	42.61	2,630	103.29	1,085	1,045
November	107,827	39.61	2,722	91.89	1,173	3,069
December	125,199	39.50	3,170	88.54	1,414	4,246
Total	1,421,967	465.46		1,084.48		25,149
Average	118,497	38.79	3,061	90.37	1,321	2,286

7.1.2 Comments:

7.2 Energy Related Processes and Equipment

7.2.1 Indicate equipment and practices utilized at your treatment facility (Check all that apply):

- Aerobic Digestion
- Anaerobic Digestion
- Biological Phosphorus Removal
- Coarse Bubble Diffusers
- Dissolved O2 Monitoring and Aeration Control

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

- Effluent Pumping
- Fine Bubble Diffusers
- Influent Pumping
- Mechanical Sludge Processing
- Nitrification
- SCADA System
- UV Disinfection
- Variable Speed Drives
- Other:

7.2.2 Comments:

7.3 Future Energy Related Equipment

7.3.1 What energy efficient equipment or practices do you have planned for the future for your treatment facility?

Installation of fine bubble aeration in the oxidation ditch with submersible mixing. Increase the aeration capacity of the oxidation ditch while reducing the horsepower required.

8. Biogas Generation

8.1 Do you generate/produce biogas at your facility?

No

Yes

If Yes, how is the biogas used (Check all that apply):

- Flared Off
- Building Heat
- Process Heat
- Generate Electricity
- Other:

9. Energy Efficiency Study

9.1 Has an Energy Study been performed for your treatment facility?

No

Yes

Entire facility

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

<input checked="" type="checkbox"/> Part of the facility Year: <input type="text" value="2017"/> By Whom: <input type="text" value="Focus on Energy and Strand Engineering"/> Describe and Comment: <input type="text" value="Looked at aeration in the oxidation ditches which are the primary energy use."/>	
--	--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 2018

Sanitary Sewer Collection Systems

1. Capacity, Management, Operation, and Maintenance (CMOM) Program

1.1 Do you have a CMOM program that is being implemented?

- Yes
- No

If No, explain:

1.2 Do you have a CMOM program that contains all the applicable components and items according to Wisc. Adm Code NR 210.23 (4)?

- Yes
- No (30 points)
- N/A

If No or N/A, explain:

1.3 Does your CMOM program contain the following components and items? (check the components and items that apply)

- Goals [NR 210.23 (4)(a)]

Describe the major goals you had for your collection system last year:

1. Clean 25 percent of the sanitary sewer collection system.
2. Clean lift station wet wells biannually.
3. Televis 5% of sanitary collection system.
4. Use 160,000 budget allotment to line clay sewer.
5. Repair failing manholes with budgeted funds.

Did you accomplish them?

- Yes
- No

If No, explain:

- Organization [NR 210.23 (4) (b)]

Does this chapter of your CMOM include:

- Organizational structure and positions (eg. organizational chart and position descriptions)
- Internal and external lines of communication responsibilities
- Person(s) responsible for reporting overflow events to the department and the public

- Legal Authority [NR 210.23 (4) (c)]

What is the legally binding document that regulates the use of your sewer system?

sewer use ordinance

If you have a Sewer Use Ordinance or other similar document, when was it last reviewed and revised? (MM/DD/YYYY) 2016-06-14

Does your sewer use ordinance or other legally binding document address the following:

- Private property inflow and infiltration
- New sewer and building sewer design, construction, installation, testing and inspection
- Rehabilitated sewer and lift station installation, testing and inspection
- Sewage flows satellite system and large private users are monitored and controlled, as necessary
- Fat, oil and grease control
- Enforcement procedures for sewer use non-compliance

- Operation and Maintenance [NR 210.23 (4) (d)]

Does your operation and maintenance program and equipment include the following:

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

- Equipment and replacement part inventories
- Up-to-date sewer system map
- A management system (computer database and/or file system) for collection system information for O&M activities, investigation and rehabilitation
- A description of routine operation and maintenance activities (see question 2 below)
- Capacity assessment program
- Basement back assessment and correction
- Regular O&M training

Design and Performance Provisions [NR 210.23 (4) (e)]

What standards and procedures are established for the design, construction, and inspection of the sewer collection system, including building sewers and interceptor sewers on private property?

- State Plumbing Code, DNR NR 110 Standards and/or local Municipal Code Requirements
- Construction, Inspection, and Testing
- Others:

Overflow Emergency Response Plan [NR 210.23 (4) (f)]

Does your emergency response capability include:

- Responsible personnel communication procedures
- Response order, timing and clean-up
- Public notification protocols
- Training
- Emergency operation protocols and implementation procedures

Annual Self-Auditing of your CMOM Program [NR 210.23 (5)]

Special Studies Last Year (check only those that apply):

- Infiltration/Inflow (I/I) Analysis
- Sewer System Evaluation Survey (SSES)
- Sewer Evaluation and Capacity Management Plan (SECAP)
- Lift Station Evaluation Report
- Others:

2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning	<input style="width: 60px; text-align: right;" type="text" value="32"/>	% of system/year
Root removal	<input style="width: 60px; text-align: right;" type="text" value="5"/>	% of system/year
Flow monitoring	<input style="width: 60px; text-align: right;" type="text" value="0"/>	% of system/year
Smoke testing	<input style="width: 60px; text-align: right;" type="text" value="0"/>	% of system/year
Sewer line televising	<input style="width: 60px; text-align: right;" type="text" value="6.6"/>	% of system/year
Manhole inspections	<input style="width: 60px; text-align: right;" type="text" value="14.5"/>	% of system/year
Lift station O&M	<input style="width: 60px; text-align: right;" type="text" value="12"/>	# per L.S./year
Manhole rehabilitation	<input style="width: 60px; text-align: right;" type="text" value="1.2"/>	% of manholes rehabbed
Mainline rehabilitation	<input style="width: 60px; text-align: right;" type="text" value="1.6"/>	% of sewer lines rehabbed

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

Private sewer inspections % of system/year
 Private sewer I/I removal % of private services
 River or water crossings % of pipe crossings evaluated or maintained

Please include additional comments about your sanitary sewer collection system below:

We have a fairly aggressive lining and manhole rehab programs. We have a system rating of 1-5 for infrastructure with 5 being the worst. We have lined a majority of the main rated at a 5 and continue to line more as we find it with our televising program. Since staff has taken over the cleaning and televising they have a lot better understanding of the system.

3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

Total actual amount of precipitation last year in inches
 Annual average precipitation (for your location)
 Miles of sanitary sewer
 Number of lift stations
 Number of lift station failures
 Number of sewer pipe failures
 Number of basement backup occurrences
 Number of complaints
 Average daily flow in MGD (if available)
 Peak monthly flow in MGD (if available)
 Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

Lift station failures (failures/year)
 Sewer pipe failures (pipe failures/sewer mile/yr)
 Sanitary sewer overflows (number/sewer mile/yr)
 Basement backups (number/sewer mile)
 Complaints (number/sewer mile)
 Peaking factor ratio (Peak Monthly:Annual Daily Avg)
 Peaking factor ratio (Peak Hourly:Annual Daily Avg)

4. Overflows

LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OFERFLOWS REPORTED **

Date	Location	Cause	Estimated Volume (MG)
0 4/27/2018 11:30:00 AM - 4/27/2018 12:30:00 PM	25 gallons from manhole #804 at 2555 Prairie Drive	Plugged Sewer	0 - 0

** If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

What actions were taken, or are underway, to reduce or eliminate SSO or TFO occurrences in the future?

A manufacturing facility was releasing a plastic that was plugging the sanitary sewer main. We worked with the facility to remove the product from the waste stream so it is not being discharged down the sewer.

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

Yes

No

If Yes, please describe:

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

Yes

No

If Yes, please describe:

5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:

Inflow has been fairly stable. We will continue to line clay sewer and rebuild man hole structures to try to reduce the amount of infiltration.

5.4 What is being done to address infiltration/inflow in your collection system?

Lining clay sanitary sewer mains, replacing open pick manhole covers with gasket lids and rehab of manholes.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/11/2019 **2018**

Grading Summary

WPDES No: 0029394

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	D	1	3	3
BOD/CBOD	A	4	10	40
TSS	A	4	5	20
Ammonia	A	4	5	20
Phosphorus	A	4	3	12
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			37	139
GRADE POINT AVERAGE (GPA) = 3.76				

Notes:

- A = Voluntary Range (Response Optional)
- B = Voluntary Range (Response Optional)
- C = Recommendation Range (Response Required)
- D = Action Range (Response Required)
- F = Action Range (Response Required)